

7380040 ANNUAL DRINKING WATER QUALITY REPORT
PWSID #: **7380040** NAME: **West Lebanon Township**

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact West Lebanon Township at 717-274-1598. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Monday of the month at 7:00pm at the West Lebanon Township Building at 322 N. 22nd Street Lebanon PA, 17046.

SOURCE(S) OF WATER:

Our water source(s) is/are: (Name-Type-Location)

8801-Well #1 North Lebanon Township

8802- Well #2 North Lebanon Township

8803- Well #3 City of Lebanon Authority (Emergency Connection)

A Source Water Assessment of our source(s) was completed by the PA Department of Environmental Protection (Pa. DEP). The Assessment has found that our source(s) of is/are potentially most susceptible to [insert potential Sources of Contamination listed in your Source Water Assessment Summary]. Overall, our source(s) has/have [little, moderate, high] risk of significant contamination. A summary report of the Assessment is available on the Source Water Assessment Summary Reports eLibrary web page: Source Water Assessment Folder. Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP South Central Regional Office, Records Management Unit at (717) 705-4700.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

Monitoring Your Water:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2024. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) – The minimum level of residual disinfectant required at the entry point to the distribution system.

Level 1 Assessment – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter ($\mu\text{g/L}$)

ppm = parts per million, or milligrams per liter (mg/L)

ppq = parts per quadrillion, or picograms per liter

ppt = parts per trillion, or nanograms per liter (ng/L)

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Total Chlorine	MRDL=4	MRDLG=4	2.09	0.22-2.09	PPM	11/26/24	N	Water additive used to control microbes
Free Chlorine	MRDL=4	MRDLG=4	2.01	0.24-2.01	PPM	11/26/24	N	Water additive used to control microbes
Nitrate-N	10	10	4.12	3.78-4.12	PPM	4/11/2024	N	Runoff from septic system or fertilizer
Nitrite-N	1	1	0	0	PPM	4/11/2024	N	Runoff from septic system or fertilizer
HAA5	60	N/A	0.00727	0.00727	PPM	7/15/2024	N	Byproduct of drinking water chlorination
Barium	2	2	0	0	PPM	1/11/2024	N	Drilling discharge waste, metal refineries, erosion or natural deposits
Chloroform	N/A	N/A	0.0070	0.0070	PPM	7/15/2024	N	By product of drinking water chlorination
Bromodichloromethane	N/A	N/A	0.0040	0.0040	PPM	7/15/2024	N	By product of drinking water chlorination
Dibromochloromethane	N/A	N/A	0.0019	0.0019	PPM	7/15/2024	N	By product of drinking water chlorination.
Total Trihalomethanes (TTHMs)	080	N/A	0.0128	0.0128	PPM	7/15/2024	N	By product of drinking water chlorination.
Bromoacetic Acid	N/A	N/A	<0.001	<0.0001	PPM	7/15/2024	N	By-product of drinking water chlorination.
Chloroacetic Acid	N/A	N/A	<0.0002	<0.0002	PPM	7/15/2024	N	By-product of drinking water chlorination.
Dibromoacetic Acid	N/A	N/A	0.001	0.001	PPM	7/15/2024	N	By-product of drinking water chlorination.
Dichloroacetic Acid (HAA)	N/A	N/A	0.004	0.004	PPM	7/15/2024	N	By-product of drinking water chlorination.
Trichloroacetic Acid (HAA)	N/A	N/A	0.002	0.002	PPM	7/15/2024	N	By-product of drinking water Chlorination.
Perfluorooctanesulfonic Acid (PFOS)	18	8	<1.9	<1.9	PPM	10/10/2024	N	Discharge from manufacturing facilities and runoff from land use activities.

Perfluorooctanoic Acid (PFOA)	8	14	<1.9	<1.9	PPM	10/102024	N	Discharge from manufacturing facilities and runoff from land use activities
Hexafluoropropylene Oxide (HFPO-DA)	N/A	N/A	<1.9	<1.9	PPM	10/102024	N	Discharge from manufacturing facilities and runoff from land use activities
Perfluorobutanesulfonic Acid (PFBS)	N/A	N/A	<1.9	<1.9	PPM	10/102024	N	Discharge from manufacturing facilities and runoff from land use activities
Perfluorohexanesulfonic Acid (PFHxS)	N/A	N/A	<1.9	<1.9	PPM	10/102024	N	Discharge from manufacturing facilities and runoff from land use activities
Gross Alpha Particle Activity	N/A	N/A	3.24	3.24	pCi/L	1/24/2024	N	Erosion of natural deposits.
Radium-226	N/A	N/A	0.260	0.260	pCi/L	1/24/2024	N	Erosion of natural deposits.
Radium-228	N/A	N/A	0.950	0.950	pCi/L	1/24/2024	N	Erosion of natural deposits.
Combined Uranium	0.67	0.67	1.21	1.21	pCi/L	2021	N	Erosion of natural deposits.

*EPA's MCL for fluoride is four ppm. However, Pennsylvania has set a lower MCL to better protect human health.

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Free Chlorine	0.40	0.90	0.90-2.14	ppm	6/2/2024	N	Water additive used to control microbes.
Total Chlorine	0.40	0.85	0.85-2.12	Ppm	4/26/2024	N	Water additive used to control microbes.

Lead and Copper								
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Range of tap sampling results	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	0.0009	0-0.0001	ppb	0	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.733	0.049-0.663	ppm	0	N	Corrosion of household plumbing.

Microbial (related to Assessments/Corrective Actions regarding TC positive results)					
Contaminants	TT	MCLG	Assessments/ Corrective Actions	Violation Y/N	Sources of Contamination
Total Coliform Bacteria	Any system that has failed to complete all the required assessments or correct all identified sanitary defects, is in violation of the treatment technique requirement	N/A	See detailed description under “Detected Contaminants Health Effects Language and Corrective Actions” section	N	Naturally present in the environment.

Microbial (related to E. coli)					
Contaminants	MCL	MCLG	Positive Sample(s)	Violation Y/N	Sources of Contamination
<i>E. coli</i>	Routine and repeat samples are total coliform-positive and either is <i>E. coli</i> -positive or system fails to take repeat samples following <i>E. coli</i> -positive routine sample or system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> .	0	0	N	Human and animal fecal waste.
Contaminants	TT	MCLG	Assessments/ Corrective Actions	Violation Y/N	Sources of Contamination
<i>E. coli</i>	Any system that has failed to complete all the required assessments or correct all identified sanitary defects, is in violation of the treatment technique requirement	N/A	See description under “Detected Contaminants Health Effects Language and Corrective Actions” section	N	Human and animal fecal waste.

Raw Source Water Microbial					
Contaminants	MCLG	Total # of Positive Samples	Dates	Violation Y/N	Sources of Contamination
<i>E. coli</i>	0	0	2024	N	Human and animal fecal waste.

DETECTED CONTAMINANTS HEALTH EFFECTS LANGUAGE AND CORRECTIVE ACTIONS:

N/A

OTHER VIOLATIONS:

Violation ID-19298- Data was late reported.

Violation ID-28213- Reported and corrected typographical error.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

INFORMATION ABOUT LEAD

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF UTILITY] is responsible for providing high quality drinking water and is removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family’s risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact [NAME OF UTILITY and CONTACT INFORMATION]. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

OTHER INFORMATION:

West Lebanon Township had no violations for the year 2024. West Lebanon Township continues to provide safe quality drinking water to its customers. For more information visit www.westlebanonpa.gov or call West Lebanon Township at 717-274-1598.

West Lebanon Township prepared a service line inventory that includes the type of materials contained in each service line in our distribution system. This inventory can be accessed online at www.westlebaonpa.gov or by contacting our office at 717-274-1598.